

ADDENDUM NO. 1

January 15, 2019

The following portions of the Bid Documents have been revised:

- Bids will be received by the Building Department at City Hall, 38020 Meridian Ave, Dade City, FL 33525 until **11:00 a.m., Wednesday, January 30, 2019** and opened shortly thereafter.
- Attachments listed below and following this page have additionally been uploaded to the City website. To access these files:
<http://www.dadecityfl.com/departments/government/BIDS/QUOTES/AUCTIONS.php>

Attachments:

- Pre-Bid Sign-in
- Construction Plans (pdf format) - online
- Responses to Bidder Set #1-3 Questions

Any additional questions regarding the bid shall be submitted, in writing, to hwashburn@DADECITYFL.com and jdebono@DADECITYFL.com by **January 23, 2019**.

Question Set #1

1. May 6" DR18 Fusible PVC C900® pipe be used for the water main HDD bid item #48?

Response: The 6" Fusible PVC may be used as an alternative to the specified pipe however any changes resulting from this substitution must be accommodated by the contractor with no additional cost to the City of Dade City. (Changes such as fittings, bending radius, etc. brought on by this substitution).

Question Set #2

1. After reviewing the bid package, it appears the plan sheets are mixed in with the specs. They also appear to be in triplicate. Can you confirm which plan sheets are to be used by uploading and posting them separate from the specs and contract documents?

Response: A separate file containing just the construction plans has been uploaded to the City's webpage

<<http://www.dadecityfl.com/departments/government/BIDS/QUOTES/AUCTIONS.php>>

Question Set #3

1. Is there an engineers estimate available?

Response: The City is not releasing the engineer's estimate.

2. The document requirements mentioned EEO certification to be submitted with the bid, along with labor standards and section 3 homes. Is there a form already prepared to fill out and submit with the bid? Where can those be found.

Response: The submittal of these documents is not necessary for this project.